

CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

RAYMOND S. CHAN, C.E., S.E.
GENERAL MANAGER

FRANK BUSH
EXECUTIVE OFFICER

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE-PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ

Grabber Construction Products, Inc.
5255 W 11000 N Ste 100
Highland, UT 84003

Attn: Ron Campbell
(801) 492-3880 x 215

RESEARCH REPORT: 25509
(CSI # 05 05 03)

BASED UPON ICC EVALUATION SERVICE
REPORT NO. ESR-1271

REEVALUATION DUE
DATE: January 1, 2018
Issued Date: April 1, 2016
Code: 2014 LABC

GENERAL APPROVAL – Reevaluation/Clerical Modification - Grabber Driveall® and Superdrive® Selfdrilling Tapping Screws.

DETAILS

Grabber Driveall® and Superdrive® Selfdrilling Tapping Screws are approved when in compliance with the description, use, identification and findings of Report No. ESR-1271, reissued July 1, 2015, revised August 1, 2015 of the ICC Evaluation Service, Incorporated. The report in its entirety is attached and made part of this general approval.

The approval is subject to the following conditions:

1. Fasteners must be installed in accordance with the manufacturer's published installation instructions and the attached ICC-ES report. In the event of a conflict between the two reports, the more restrictive governs.
2. The utilization of the screws in cold-formed steel deck diaphragms is outside the scope of the approval.
3. Calculations and drawings verifying compliance with this report and the 2014 Los Angeles Building Code must be submitted to the plan check engineer. The drawings shall be prepared by a Civil or Structural Engineer registered in the State of California.

RR25509
Page 1 of 2

Grabber Construction Products, Inc
RE: Grabber Driveall® and Superdrive® Selfdrilling Tapping Screws.

4. For ASD, the allowable screw strength or screw connection is not to be increased for short duration loads such as wind or earthquake loads.

DISCUSSION

The clerical modification is to change the organization address and contact person.

The report is in compliance with the 2014 Los Angeles City Building Code.

The approval is based on tests in accordance with the ICC ES Acceptance Criteria for Tapping Screw Fasteners (AC 118), dated April 2015.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revision to the report must be submitted to this Department for review with appropriate fee to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

QUAN NGHIEM, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

QN
RR25509/MSWord2013
R3/18/16
TLB1600054
104.2.6

Attachments: ICC-ES Report ESR-1271 (5 Pages)